

LOCATION		5338 Goble St.		CITY		GASTON	
BETWEEN		Olney Church Rd		STREET &		HURFMAN ST	
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED	
MAIN TO BLDG	3/4"	P	56'	5-10-99			
MAIN TO PROP LINE	3/4"	P	10'				
PROP LINE TO BLDG	3/4"	P	46'				
ENTERS		3338		BRANCHED INTO			
TAP SIZE	1/2	PRESSURE	60 PSI	INCHES W.C.	LOCATION 114' N. of center of Olney Church Rd.		
PRESSURE TEST @		100 PSI	FOR	1/4 HRS	BY	S.G.	
MAIN SIZE	2"	C I		RARE STEEL	COATED STEEL	PLASTIC	YEAR INSTALLED 1967
DEPTH	3 FT	0 IN	LOCATION 8' E of center of Goble St.				
"A" P/S READING		1.3		TOTAL ANODES 1#		0	17# 0
				LR #		372306	

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	S	
P/S Pipeline Lead White Existing Main	E	