

LOCATION 2625 Golden Bell Dr. CITY Catskill
BETWEEN Olive Ct. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5'0"</u>	<u>P</u>	<u>87'</u>	<u>10-10-02</u>		
MAIN TO PROP LINE	<u>5'8"</u>	<u>P</u>	<u>40'</u>			
PROP LINE TO BLDG	<u>5'8"</u>	<u>P</u>	<u>45'</u>			

ENTERS 2625 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 74' N. of center of Golden Bell Dr.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.H.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 2002

DEPTH 3 FT 0 IN LOCATION 18' W. of center of Olive Ct.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 288059

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead White Existing Main	<u>E</u>	