

LOCATION 602 N. Grace st. CITY East.
BETWEEN Beatrice Costner STREET & Allison st. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>114'</u>		<u>9-</u>	<u>8-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>..</u>	<u>22'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>92'</u>			

ENTERS: SAME

BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 155' From @ of
Beatrice Costner


PRESSURE TEST. @ 100 PSI FOR 1/4 HRS BY D.F.

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH 2 FT 8 IN. LOCATION W. OF Grace st.

"A" P/S READING P. TOTAL ANODES 1# - 17# - LR # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY