

LOCATION 610 Grace st. CITY GASTONIA  
BETWEEN Beatrice costner STREET & Allison st. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>123'</u>		<u>9-</u>	<u>9-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>22'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>101'</u>			


ENTERS: SAME BRANCHED INTO  
TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 310' from @ of  
Beatrice costner

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY DF.  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 2 FT. 8 IN. LOCATION W. OF Grace st.

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY