

LOCATION 1914 GRAHAM ST CITY GALETONIA
BETWEEN BISSEMER CITY RD STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>D</u>	<u>64'</u>	<u>8-13-97</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>D</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>D</u>	<u>59'</u>			

ENTERS 1914 BRANCHED INTO 0
TAP SIZE 3/8 PRESSURE 100 PSI INCHES W.C. LOCATION


PRESSURE TEST 100 PSI FOR 1/4 HRS BY ED

MAIN SIZE 2" C I BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED

DEPTH 3 FT 0 IN LOCATION

"A" P/S READING 1.2 TOTAL ANODES 1# 17# LR #

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	<u>0.105</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	<u>0.105</u>