

LOCATION 202 W. Granite Ave CITY GASTONIA

BETWEEN Falls St. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>9'</u>			<u>5-30-96</u>
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>1'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>8'</u>			

ENTERS: 202 W. Granite Ave BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 68' North from Center of Granite.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY ML

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION 12' from Falls St.

"A" P/S READING P TOTAL ANODES 1# 17 L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY