

LOCATION 206<sup>E</sup> Granite Ave CITY CASTONIA  
BETWEEN Oakland St. STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>45'</u>		<u>2-1596</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>16'</u>		<u>32' of 3/4" cfw</u>	
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>29'</u>			

ENTERS: 206 Granite Ave BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 5' South of Granite

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY mlf  
MAIN-SIZE 2" C.I.        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 1986  
DEPTH: 3 FT. 0 IN. LOCATION South Side of Granite Ave.

"A" P/S READING P TOTAL ANODES 1#        17# ✓ L.R. #       

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<b>S</b>		
	P/S Pipeline Lead - White Existing Main	<b>E</b>		