

LOCATION 209 Granite St. CITY ASTORIA
BETWEEN Falls St. STREET & York St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>40'</u>	<u>1-31-96</u>	<u>70' 1" Bare Service</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>5'</u>		<u>Pipe.</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>35'</u>			

ENTERS: 213 BRANCHED INTO: 209
TAP SIZE: 3/8" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 253' W of C of Falls St.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

MAIN-SIZE 1 1/4 C.I. _____ BARE STEEL ☒ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1958

DEPTH. 2 FT. 0 IN. LOCATION 12' S of C of Granite St.

"A" P/S READING .40 TOTAL ANODES 1# _____ 17# 1 L.R. # N/A

REMARKS. Temp. Renewed Service 2 weeks then house will be torn down.
See leak sheet.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT USE ONLY