

LOCATION 214 W. Granite Ave CITY GASTONIA
BETWEEN Falls Ave STREET & N. York St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>73'</u>			<u>5-9-96</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>30'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>43'</u>			

ENTERS: 214 W. Granite Ave BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 11' south of Granite Ave


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY ml

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 96

DEPTH: 3 FT. 0 IN. LOCATION South Side of Granite Ave

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>		
	P/S Pipeline Lead - White Existing Main	<u>E</u>		