

LOCATION 215 W. Granite Ave CITY Gastonia
BETWEEN Falls STREET & N. York STREET


| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|-----------|-------------|------------|-----------|----------------|---------|
| MAIN TO BLDG. | <u>1"</u> | <u>Bare</u> | <u>27'</u> | | <u>3-15-96</u> | |
| MAIN TO PROP. LINE | | | | | | |
| PROP. LINE TO BLDG. | | | | | | |

ENTERS 215 BRANCHED INTO: 2
TAP SIZE: 1" 5in PRESSURE 20 PSI _____ INCHES W.C. LOCATION _____

PRESSURE TEST: @ _____ PSI FOR _____ HRS. BY _____
MAIN SIZE 1" C.I. _____ BARE STEEL ☒ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1937
DEPTH: 2 FT. 6 IN. LOCATION _____

"A" P/S READING 1.6 TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS:
No Anode Installed, Bare main in process of being Retired & Reamed



| Test Station | | |
|--|----------|----------------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>S</u> | <u>Retired</u> |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |

ENG. DEPT USE ONLY