

LOCATION 506 W. Granite Ave. CITY GAST.
BETWEEN Ford's Alley STREET & Boyce STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>9'</u>		<u>3.13</u>	<u>-96</u>
MAIN TO PROP. LINE	<u>1"</u>	<u>"</u>	<u>1'</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>1"</u>	<u>8'</u>			

ENTERS: 506 W. Granite BRANCHED INTO:
TAP SIZE: 1/2" PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION N. Side of 506


PRESSURE TEST: @ 180 psi For 1/4 Hrs. By GK

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC / YEAR INSTALLED 96

DEPTH: 3 Ft. _____ In. LOCATION E Side of Ford's Alley

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY