

LOCATION 611 W. GRANITE AVE CITY GASTONIA

BETWEEN PYOR STREET & CHERRY STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	$\frac{3}{4}$ "	P	85'		5-1	96
MAIN TO PROP. LINE	"	"	30'			
PROP. LINE TO BLDG.	"	"	55'			

ENTERS: 611 Granite BRANCHED INTO:

TAP SIZE: $\frac{3}{4}$ " PRESSURE 60 PSI _____ INCHES W.C. LOCATION W. of 611


PRESSURE TEST: @ 180 PSI FOR 1 1/4 HRS. BY GN

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 96

DEPTH: 3 FT. _____ IN. LOCATION N. Side of W. GRANITE

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY