

LOCATION 614 W. Granite Ave. CITY GAST.
BETWEEN Pryor STREET & CHERRY STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	33'		5 - 1	-96
MAIN TO PROP. LINE	"	"	5'			
PROP. LINE TO BLDG.	"	"	28'			

ENTERS: 614 W. Granite BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION E. Side of House

PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS. BY GLK
MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 96
DEPTH: 3 FT. IN. LOCATION N. Side of W. Granite

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>7</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY