

LOCATION 216 W Granite Ave CITY GASTONIA

BETWEEN Pryor STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	22' EXIST	TIED OVER 12-8-96		
MAIN TO PROP. LINE			6' NEW P			
PROP. LINE TO BLDG.			28' Total			

ENTERS: 712 BRANCHED INTO: 716

TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 192' W OF N Pryor

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY M Parker

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION 12' N OF W Granite

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>P-RISER</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY