

LOCATION 1921 Greystone DR. CITY GASTONIA

BETWEEN Greystone ct STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	Plastic	104'	12/14/96		
MAIN TO PROP. LINE	3/4"		15'			
PROP. LINE TO BLDG.	3/4'		89'			

ENTERS. 1921 BRANCHED INTO:

TAP SIZE: 1/2" PRESSURE 60 PSI _____ INCHES W C LOCATION South side of 1921


PRESSURE TEST @ 100 PSI FOR 1/4 HRS. BY DT

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1994

DEPTH 3 FT 0 IN. LOCATION West side of Greystone DR.

"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. # 721470

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S		
	P/S Pipeline Lead - White Existing Main	E		