

LOCATION 1924 Greystone Dr. CITY CASTONIA
BETWEEN 1920 Greystone Dr. STREET & Greystone Ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>35'</u>	<u>10-5-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>25'</u>			

ENTERS: 1928 BRANCHED INTO: 1924
TAP SIZE: 3/4 straight tee PRESSURE 60 P.S.I. _____ INCHES' W.C. LOCATION 70' N of C of Greystone Ct.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BL

~~Service~~ MAIN SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1994

DEPTH: 2 Ft. 0 In. LOCATION: 111' E of C of Greystone Dr.

"A" P/S READING Plastic TOTAL ANODES 1* _____ 17* _____ L.R. # 398001

REMARKS: new 3/4 split Plastic Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser PLASTIC</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY