

LOCATION 1925 Greystone Dr. CITY GASTONIA
BETWEEN Greystone Ctr. STREET & 1921 Greystone Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>90'</u>	<u>10-7-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>18'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>72'</u>			

ENTERS: 1925 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 118' N of C of Greystone Ctr.


PRESSURE TEST: @ 100 psi. For 1/4 Hrs. By RL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1994

DEPTH: 3 Ft. 0 In. LOCATION 12' W of C of Greystone Dr.

"A" P/S READING Plastic TOTAL ANODES 1# _____ 17# _____ L.R. # 398001

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Rise!</u> <u>Plastic</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY