

LOCATION 1928 Grey Stone Dr. CITY GASTONIA  
BETWEEN Grey Stone Ct. STREET & 1924 Grey Stone Dr. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>139'</u>	<u>10-5-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>28'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>111'</u>			

ENTERS: 1928 BRANCHED INTO: 1924  
TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 70' W of Grey Stone Ct.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1994  
DEPTH: 3 Ft. 0 In. LOCATION 13' W of Grey Stone Dr.

"A" P/S READING Plastic TOTAL ANODES 1\* \_\_\_\_\_ 17\* \_\_\_\_\_ L.R. # 398001

REMARKS: New 3/4 Plastic Service with Road Bore. with Road Bore.  
1924 Grey Stone Splits off 1928 see w.o. 093875



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY