

LOCATION 1935 Grey Stone Dr. CITY GAstonia
BETWEEN Linwood Rd. STREET & Grey Stone Ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>90'</u>	<u>10-8-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>18'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>72'</u>			

ENTERS: 1935 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 140' S of C of Grey Stone Ct.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1994

DEPTH: 3 Ft. 0 In. LOCATION 14' W of C of Grey Stone Dr.

"A" P/S READING Plastic TOTAL ANODES 1# 17# L.R. # 398001

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY