

LOCATION 3902 Graywood Dr. CITY Castain

BETWEEN Laurel Woods Dr STREET & Crawley Woods Dr STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	114'	8-14-00		
MAIN TO PROP LINE	3/4"	P	10'			
PROP LINE TO BLDG	3/4"	P	104'			

ENTERS 3902 BRANCHED INTO

TAP SIZE 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 460' W. of Center of Crawley Woods Dr


PRESSURE TEST @ 100 PSI FOR 44 HRS BY S.L.H.

MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1999

DEPTH 3 FT 0 IN LOCATION 18' S. of center of Graywood Dr

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 711268

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	