

LOCATION 3901 Graywood DR CITY BASTONIA

BETWEEN LAUREL WOODS DR. STREET & DEAD END STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>112'</u>	<u>12-19-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>72'</u>			

ENTERS: 3901 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES WC LOCATION 781' E of center of

LAUREL WOODS DR


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. HUFFSTETTER

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN LOCATION 17' S. of center of Graywood DR

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 865180

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY