

LOCATION 3109 GRAYWOOD DR. CITY GASTONIA
BETWEEN CANDLEWOOD DR. STREET & CROWDEPS WOODS DR. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>PL</u>	<u>118'</u>	<u>11.14.01</u>		
MAIN TO PROP LINE	<u>-</u>	<u>-</u>	<u>46'</u>	<u>-</u>		
PROP LINE TO BLDG	<u>-</u>	<u>-</u>	<u>172'</u>	<u>-</u>		

ENTERS

BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W/C LOCATION WEST SIDE


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY J. BOWEN

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC - YEAR INSTALLED _____

DEPTH 3 FT IN LOCATION SOUTH SIDE OF GRAYWOOD DR.

"A" P/S READING NA TOTAL ANODES 1# _____ 17# _____ LR # _____

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	