

LOCATION 118 GREEN DR. CITY CASTANIA  
BETWEEN Franklin Blvd STREET & EAST CLUB STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>88'</u>		<u>12-18-97</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>33'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>55'</u>			

ENTERS: SAME BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI          INCHES W C LOCATION 404' FROM C.O.F  
Franklin Blvd.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY D.F.  
MAIN-SIZE 2" C.I.          BARE STEEL          COATED STEEL          PLASTIC ✓ YEAR INSTALLED 1997  
DEPTH: 3 FT. 0 IN LOCATION W. OF GREEN DR.

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY