

LOCATION 1007 GREEN circle Dr. CITY East.

BETWEEN CENTER st. STREET & MIDWAY Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>146'</u>		<u>8.</u>	<u>5-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>37'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>10 9'</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI          INCHES W.C. LOCATION 117' from @ of

CENTER st.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY D.F.

MAIN-SIZE 2" C.I.          BARE STEEL          COATED STEEL          PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT 0 IN. LOCATION East. of Green circle

"A" P/S READING P. TOTAL ANODES 1#          17#          L.R. #         

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY