

LOCATION 1021 Green circle CITY East.
BETWEEN CENTER st. STREET & MIDWAY Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>77'</u>		<u>8-</u>	<u>6-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>15'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>62'</u>			


ENTERS: SAME BRANCHED INTO: 1023 Green circle
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W/C LOCATION 355' From @ of
Center st.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY D.F.
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN LOCATION E. of Green circle

"A" P/S READING P. TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY