

LOCATION 1023 Green Circle CITY East.
BETWEEN LESTER ST. STREET & MIDWAY DR. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>102'</u>		<u>8-6-97</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>38'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>64'</u>			


ENTERS: JAME BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 354' FROM @ OF
LESTER ST.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.F.
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION E. OF Green Circle Dr.

"A" P/S READING P. TOTAL ANODES 1# _____ 17# 7 L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY