

LOCATION 1119- Green circle CITY Gast  
BETWEEN Midway Dr. STREET & Center St. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>38'</u>		<u>8.6.97</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>TIE OVER.</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>				

ENTERS: SAME BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 479' from @  
of Midway

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY O.F.  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1997  
DEPTH: 3 FT. 0 IN. LOCATION S. of Green circle

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY