

LOCATION 1141 Green Circle CITY East.
BETWEEN Midway Dr. STREET & Pentecost. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>33'</u>		<u>8-</u>	<u>8-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>8'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>25'</u>			

ENTERS: SAME BRANCHED INTO: 1135 Green Circle
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 221' From @ of

Midway Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.R.

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC — YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION S. of Green Circle

"A" P/S READING P. TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY