

LOCATION 1142 Green circle CITY East.

BETWEEN Midway Dr. STREET & Center st. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>95'</u>		<u>8-11-97</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>6'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>89'</u>			

ENTERS: Same BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 106' From (C) of

Midway Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.F.

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION S. of Green circle Dr

"A" P/S READING P. TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY