

LOCATION 1215 GREEN Circle

CITY GASTONIA

BETWEEN PARKVIEW Dr.

STREET & Midway Dr.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P.	139'		8-	12-97
MAIN TO PROP. LINE	"	"	37'			
PROP. LINE TO BLDG.	"	"	102'			

ENTERS: SAME

BRANCHED INTO:

TAP SIZE:  $3/4''$

PRESSURE 60 PSI            INCHES W.C.

LOCATION 190' From @ of  
PARLVIEW Dr.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.F.


MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION S. OF Green circle

"A" P/S READING P.

TOTAL ANODES 1# 1 17# 1 L.R. # 1

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY