

LOCATION 1224 GREEN circle Dr.CITY GASTONIABETWEEN PARKVIEW Dr.STREET & MIDWAY Dr.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	148'		8.	12-97
MAIN TO PROP. LINE	"	"	6'			
PROP. LINE TO BLDG.	"	"	142'			

ENTERS: SAME

BRANCHED INTO:

TAP SIZE: 3/4"PRESSURE 60 PSI

INCHES W.C.

LOCATION 188' From (C)OF PARKVIEWPRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.F.MAIN-SIZE 2"


C.I. _____

BARE STEEL _____

COATED STEEL _____

PLASTIC ☒YEAR INSTALLED 1997DEPTH: 3 FT. 0 IN.LOCATION S. of Green circle"A" P/S READING PTOTAL ANODES 1# — 17# —L.R. # —

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY