

LOCATION 4303 GREENHAVEN LN CITY CASPER
BETWEEN WINTERWOOD DR STREET & APPLEGATE RD STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>50'</u>	<u>1-27-01</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>2'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>43'</u>			

ENTERS 4303 BRANCHED INTO 0
TAP SIZE 3/8 PRESSURE 60 PSI INCHES W C LOCATION 114' S OF C OF WINTERWOOD DR


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY PUR

MAIN-SIZE 2" C I BARE STEEL COATED STEEL 1 PLASTIC YEAR INSTALLED 1965

DEPTH FT IN LOCATION 23' W OF C OF GREENHAVEN LN

"A" P/S READING 1.3 TOTAL ANODES 1# 0 17# 0 LR # 00048155

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>0.95V</u>
P/S Pipeline lead - White Existing Main	<u>E</u>	<u>0.15V</u>