

LOCATION 4315 Greenhaven Ln CITY GASTONIA

BETWEEN Applegate STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>71'</u>			<u>9-16-89</u>
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>66'</u>			

ENTERS 4315 BRANCHED INTO 0

TAP SIZE: 3/8 PRESSURE 60 PSI INCHES W C LOCATION

PRESSURE TEST. @ 100 PSI FOR 1/4 HRS BY EP

MAIN-SIZE 2" C I BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1967

DEPTH: 4 FT 6 IN LOCATION

"A" P/S READING 1.2 TOTAL ANODES 1# 0 17# 0 L.R. #

REMARKS.

Main - White

Service Red

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	E	