

LOCATION 3516 Gregg St CITY CORASTONIA
BETWEEN BRANDING IRON STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>CI</u>	<u>3'</u>	<u>Rejoined 4-16-01</u>		
MAIN TO PROP LINE						
PROP LINE TO BLDG						

ENTERS 3516 BRANCHED INTO 0
TAP SIZE 3/4 IN. PRESSURE 600 PSI _____ INCHES W C LOCATION _____

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY EP
MAIN SIZE 3/4 C I _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED _____
DEPTH 1 FT 6 IN LOCATION _____

"A" P/S READING 1.0 TOTAL ANODES 1# — 17# — LR # _____

REMARKS _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>P/S</u>	<u>1.0</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	