

LOCATION 4218 Trier St CITY Los Angeles

BETWEEN Old York Rd STREET & Kickapoo STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>136</u>	<u>8-18-74</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>36</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>100</u>			

ENTERS: 4218 BRANCHED INTO:

TAP SIZE: 3/8 PRESSURE \_\_\_\_\_ P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION Side house


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By Bennett

MAIN-SIZE 2 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1961

DEPTH: 2 Ft. 6 In. LOCATION 11' W of C.A. St

"A" P/S READING 90 TOTAL ANODES 1\* \_\_\_\_\_ 17\* \_\_\_\_\_ L.R. # 00353265

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY