


LOCATION 4334 Grier St CITY GASTONIA
 BETWEEN KILKAPPOO AVE STREET & 2ND STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|-------------------|------------|-----------|------------|-----------|---------|---------|
| MAIN TO BLDG | <u>3/4</u> | <u>P</u> | <u>80'</u> | | | |
| MAIN TO PROP LINE | <u>1"</u> | <u>1"</u> | <u>30</u> | | | |
| PROP LINE TO BLDG | <u>1"</u> | <u>1"</u> | <u>50</u> | | | |

 ENTERS 4334 Grier St BRANCHED INTO N/A
 TAP SIZE 5/8 PRESSURE 60 PSI _____ INCHES WC LOCATION North Side
OF 4334 Grier St
 PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Cook
 MAIN SIZE 2" C I _____ BARE STEEL _____ COATED STEEL L PLASTIC _____ YEAR INSTALLED 1961
 DEPTH 2 FT 6 IN LOCATION 6' West of Center of Grier St
 "A" P/S READING 1.1 TOTAL ANODES 1# _____ 17# _____ LR # _____
 REMARKS Run New 3/4 Plastic Service



| Test Station | | |
|---|----------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>S</u> | |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |