

LOCATION 4612 Greer St CITY Gastonia

BETWEEN Homestead Dr STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>107'</u>	<u>9-16-00</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>P</u>	<u>40'</u>			
PROP LINE TO BLDG	<u>5/8"</u>	<u>P</u>	<u>67'</u>			

ENTERS 4612 BRANCHED INTO.

TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 300' E. of center of Homestead Dr


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY SM

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1996

DEPTH 3 FT 0 IN LOCATION 19' S. of center of Greer St

"A" P/S READING 7 TOTAL ANODES 1# 0 17# 0 LR # 270966

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	