

LOCATION 4618 Grier St. CITY Gastonia
BETWEEN Homestead STREET & Plaza STREET


| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------|------|--------|-----------|---------|---------|
| MAIN TO BLDG. | 3/4" | P | 122' | 1. 17.96 | | |
| MAIN TO PROP. LINE | " | " | 44' | | | |
| PROP. LINE TO BLDG. | " | " | 78' | | | |

ENTERS: 4618 Grier St. BRANCHED INTO:
TAP SIZE: 1/2" PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION E Side of 4618

PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By GL
MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 96
DEPTH: 3 Ft. _____ In. LOCATION South side of Grier St.

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



| Test Station | | |
|--|------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | P |
| P/S Pipeline Lead - White Existing Main | E | |

ENG. DEPT. USE ONLY