

LOCATION 4704 Grier St. CITY GASTONIA  
BETWEEN April St. STREET & PLAZA St. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>97'</u>	<u>11-22-95</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>47'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>50'</u>			

ENTERS: 4704 BRANCHED INTO: 0  
TAP SIZE: 3/8 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 68' w of C of PLAZA St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY: RL  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ✓ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1972  
DEPTH: 3 FT. 0 IN. LOCATION 14' S of C of Grier St.

"A" P/S READING 1.1 TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # 574479

REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser PLASTIC</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>		