

LOCATION 4109 GRissom ct. CITY Gastonia

BETWEEN old YORK Rd STREET & KickpoD STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	112'	8-5-98		
MAIN TO PROP. LINE	"	"	40'			
PROP. LINE TO BLDG.	"	"	72'			

ENTERS: 4109 BRANCHED INTO: —

TAP SIZE: 1/2 PRESSURE \_\_\_\_\_ PSI \_\_\_\_\_ INCHES W.C. LOCATION 18' N. of C of  
Grissom ct.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY JP

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1992

DEPTH: 3 FT. 0 IN. LOCATION \_\_\_\_\_

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S R</u>	<u>P</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>		