

LOCATION 401 N Graver St CITY GASTONIA
BETWEEN Gum STREET & McFarland STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>2"</u>	<u>Plastic</u>	<u>90'</u>	<u>2/23/96</u>		
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>90'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>90'</u>			

ENTERS: 401 BRANCHED INTO:
TAP SIZE: 2" PRESSURE 60 PSI _____ INCHES W.C. LOCATION N side of 401


PRESSURE TEST: @ 100 PSI FOR 3 HRS. BY DT

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION West side of McFarland

"A" P/S READING _____ TOTAL ANODES 1# 0 17# 0 I.R. # 075434

REMARKS:

	Test Station		ENG. DEPT. USE ONLY
	Reading & Location	Lead	
	P/S Pipeline Lead - Red New Service	<u>S</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>	