

LOCATION 502 Grovont ST. CITY GASTON, N.C.

BETWEEN INGENISH DR. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>136'</u>	<u>7-2-99</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>120'</u>			

ENTERS: 502 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 1164' NE. of center of INGENISH DR

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.C.H.

MAIN SIZE 2" C.I.        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 1998

DEPTH 3 FT 0 IN LOCATION 38' SE. of center of Grovont ST

\*A\* P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 543050

REMARKS:

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

