

LOCATION 3001 Hampton Circle CITY GASTON
BETWEEN Hovis Ct STREET & Hampton Circle STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Phstr</u>	<u>104'</u>	<u>11/17/97</u>		
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>42'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>62'</u>			

ENTERS: 3001 BRANCHED INTO: -
TAP SIZE: 3/8 PRESSURE 60 PSI INCHES W.C. LOCATION

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY SE
MAIN-SIZE 4" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1978
DEPTH: 3 FT. 0 IN. LOCATION

"A" P/S READING .95 TOTAL ANODES 1# 0 17# 0 L.R. # 773464

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Riscu Phstr</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY