

LOCATION 3648 E. HAMPTON DRCITY GastoniaBETWEEN TRABERTSTREET & KENNEDY

STREET

	SIZE	TYPE	LENGTH	INSTALLED	<u>Relocated</u>	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>48'</u>		<u>3-13-97</u>	
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						


ENTERS: 3648BRANCHED INTO: ~TAP SIZE: 3/4

PRESSURE _____ PSI _____ INCHES W.C.

LOCATION 76' W. of Cap
E. Hampton DrPRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY JPMAIN-SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997DEPTH: 1 FT. 6 IN. LOCATION _____"A" P/S READING P

TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red, New Service	<u>OR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY