

LOCATION 3649 E. HAMPTON DR CITY Gastonia  
BETWEEN TRABERT STREET & KENNEDY STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>123'</u>	<u>4-7-97</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>48'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>75'</u>			


ENTERS: 3649 BRANCHED INTO:         
TAP SIZE: 1/2 PRESSURE        PSI        INCHES W.C. LOCATION 20' N. of Cap  
C. Hampton Dr.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY R&L JP  
MAIN-SIZE 2" C.I.        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 1995

DEPTH: 3 FT. 0 IN. LOCATION       

"A" P/S READING P TOTAL ANODES 1#        17#        L.R. #       

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>OR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY