

LOCATION 124 Hamrick Rd. CITY CASTONIA
BETWEEN Cramer Mt. Rd. STREET & Dead End. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>80'</u>	<u>8-21-95</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>70'</u>			

ENTERS: 124 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 600 P.S.I. _____ INCHES W.C. LOCATION 615' S of C of Cramer Mt. Rd.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By AL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1995

DEPTH: 4 Ft. 0 In. LOCATION 13' E of C of Hamrick Rd.

"A" P/S READING PLASTIC N/A TOTAL ANODES 1* _____ 17* _____ L.R. # 412107

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Riser PLASTIC</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY