

LOCATION 1663 Hargrove Ave (R. Smith Inc) CITY GASTANIA  
BETWEEN Northwest Blvd STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>Cu</u>	<u>6'</u>	<u>11/8/95</u>		
MAIN TO PROP. LINE	<u>3/4"</u>		<u>6'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>		<u>6'</u>			

ENTERS: 1663 BRANCHED INTO:  
TAP SIZE: 3/8" PRESSURE 60 P.S.I. INCHES W.C. LOCATION West side of 1663

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DT  
<sup>ser</sup> MAIN - SIZE 3/4" C.I.    BARE STEEL    COATED STEEL    PLASTIC    YEAR INSTALLED 1972  
DEPTH: 1 Ft. 6 In. LOCATION West side of 1663

"A" P/S READING 1.50 TOTAL ANODES 1\* 0 17\* 0 L.R. #   

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY