

LOCATION	1205 HARPER Rd.			CITY	GASTONIA	
BETWEEN	Eastridge Dr		STREET &	Dewwood		STREET
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	90'	5-5-95		
MAIN TO PROP. LINE	3/4"	P	40'			
PROP. LINE TO BLDG.	3/4"	P	50'			

ENTERS: 1205 BRANCHED INTO:


TAP SIZE: 1/2	PRESSURE 60 P.S.I.	INCHES W.C.	LOCATION 1205 50' S. of center of Eastridge Dr
---------------	--------------------	-------------	---

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Huffstader

MAIN-SIZE 2"	C.I. <input type="checkbox"/>	BARE STEEL <input type="checkbox"/>	COATED STEEL <input type="checkbox"/>	PLASTIC <input checked="" type="checkbox"/>	YEAR INSTALLED 1995
DEPTH: 3 Ft.	0 In.	LOCATION 12' E. of center of Harper Rd			

"A" P/S READING P	TOTAL ANODES 1* 0 17* 0	L.R. # 197996
-------------------	-------------------------	---------------

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY