

LOCATION 806 + 808 E. HARRISON

CITY Gastonia

BETWEEN N. Rhyne

STREET & N. Aven

STREET

	SIZE	TYPE	806 LENGTH 808	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/8	PL	134' 80'		7-19-02	
MAIN TO PROP LINE	3/8	PL	26' 43'			
PROP LINE TO BLDG	3/8	PL	108' 38'			

ENTERS. 806

BRANCHED INTO 808

TAP SIZE 5/8 PRESSURE 60 PSI INCHES WC LOCATION

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY SE

MAIN-SIZE 6" C I BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1953


DEPTH 3 FT 0 IN LOCATION

"A" P/S READING 1.075

TOTAL ANODES 1# 17# LR #

REMARKS

Note: Retire 130' 3/4 Bape AT 806
 Retire 79' 3/4 CLW AT 808



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	R1525	PL
P/S Pipeline Lead - White Existing Main	E	