

LOCATION 906 E. HARRISON AVE CITY GASTONIA
 BETWEEN N. Rhyne - STREET & Chestnut St STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8</u>	<u>PL</u>	<u>141'</u>		<u>7-22-02</u>	
MAIN TO PROP LINE	<u>5/8</u>	<u>PL</u>	<u>25'</u>			
PROP LINE TO BLDG	<u>5/8</u>	<u>PL</u>	<u>116'</u>			


ENTERS 906 BRANCHED INTO -
 TAP SIZE 3/8 PRESSURE 60 PSI INCHES W C LOCATION

PRESSURE TEST @ 150 PSI FOR 1/4 HRS BY S.E.

MAIN-SIZE 1 1/2" C I BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1953
 DEPTH 3 FT 0 IN LOCATION

"A" P/S READING 1.0 TOTAL ANODES 1# - 17# - LR #

REMARKS
15'4" Retire Pipe



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Risen</u>	<u>PL</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	